WORLD TRADE CENTER

1 World Trade Center, Suite 36 South
New York, NY 10048 0682
212 435 8839
212 435 5231 Fax

Plant & Structures,
Planning & Construction

December 4, 1995

Mr. George Dole
Capital Management
Yamaichi International, Inc.
Two World Trade Center
Suite 9868
New York, NY 10048

Dear Mr. Dole:

The following is in response to your request as to whether asbestos was contained in the various materials used to fireproof the structural steel and decking above the ceiling level on the 98th floor of Two World Trade Center.

Extensive sampling and testing has been performed on these materials used to fireproof the structural steel and decking above the ceiling level on the floors of The World Trade Center. All sampling of fireproofing material was conducted in accordance with procedures outlined in the United States Environmental Protection Agency (USEPA) publication, "Guidance for Controlling Asbestos Containing Material in Buildings". The testing of these samples was conducted at the laboratory of the Port Authority Asbestos Management Division which is a participant in the USEPA Bulk Asbestos Sample Quality Assurance Program.

The results of the tests, in accordance with applicable guidelines are as follows:

FLOOR	SAMPLES	NO. OF SAMPLES POSITIVE FOR ASBESTOS CONTAINING MATERIALS	% OF ASBESTOS IN EACH POSITIVE SAMPLES
Floor 98	36	-0-	-0-

PLAINTIFF'S EXHIBIT
PX-743

As in most tenant spaces in the World Trade Center, your leasehold area may contain vinyl asbestos floor tiles which were installed during the initial construction of the World Trade Center. These tiles are probably in good condition and as you know, if not disturbed, are safe.

Port Authority staff is available to review with you and your representatives the sampling and testing that was employed, the methodology used to analyze the test results, the detailed results of the tests of each sample and the location on the floor from which each sample was obtained.

Sincerely,

Frank Boyce

Frank Boyce
WTC Asbestos Program Coordinator

cc: G. Melendez

bcc: R. Cronin, H. Henschel